

Minnesota Department of Health

An atmospheric vacuum breaker integrally mounted on a faucet that is connected to a chemical/soap dispenser shall be protected against back pressure by the installation of a side-kick device and a backflow preventer complying with ASSE Std. 1052. The backflow preventer shall be installed on the side outlet of the side-kick device. This requirement together with ASSE Std. 1055 shall dictate installation requirements for chemical/soap dispensers. No wye connector that has an integral shutoff shall be connected to a faucet that has an integral atmospheric vacuum breaker.

