

# IAPMO RESEARCH AND TESTING, INC.

5001 East Philadelphia Street, Ontario, California 91761-2816 – USA • 909-472-4100 • 909-472-4244 • www.iapmort.org



## CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

The most updated information on this Certificate of Listing is available online at [pld.iapmo.org](http://pld.iapmo.org)

Effective Date: December 2018

Void After: December 2019

Product: Vacuum Breakers (Atmospheric)

File No. 5918

Issued To: Hydro Systems Co.  
3798 Round Bottom Rd  
Cincinnati, OH 45244

Identification: Atmospheric type vacuum breaker assemblies shall be permanently and legibly marked with manufacturer's name or trademark, model number, maximum rated working pressure and temperature, nominal valve size, direction of water flow, and "B64.1.1". If applicable, markings shall include the critical level and "Deck Mounted". Product shall also bear the cUPC® certification mark. Markings shall be either cast, etched, stamped or engraved on the body on the assembly or on a durable metal plate securely fastened to the assembly.

Characteristics: Pipe-applied atmospheric type vacuum breakers to be installed in accordance with the manufacturer's instructions and the requirements of the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

  
Chairman, Product Certification Committee

  
CEO, The IAPMO Group



This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.



# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

Void After: December 2019

Product: Vacuum Breakers (Atmospheric)

File No. 5918

Issued To: Hydro Systems Co.

Uniform Plumbing Code (UPC®)  
National Plumbing Code of Canada  
International Plumbing Code (IPC®)

Products are in compliance with the following standard(s):

ASSE 1001-2017 and CSA B64.1.1-2011 (R2016) including Updates No. 1 and No. 2  
dated September 2015 and November 2015



# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

Void After: December 2019

Product: Vacuum Breakers (Atmospheric)

File No. 5918

Issued To: Hydro Systems Co.

### MODELS:

<u>Model No.</u>	<u>Description</u>
10092530	1/4" Atmospheric Type Vacuum Breaker